



131 Regalcrest Court  
Woodbridge, ON L4L 8P3  
Tel: (905) 856-7550  
Fax: (905) 856-4367  
Toll free: 1-800-263-2353

## TECHNICAL SPECIFICATION

### Hydro Quebec PVC Ultra Duct Conduit Fabricated Duct Coupling

#### SCOPE

This specification covers the requirements for Fabricated Hydro Quebec PVC (polyvinyl chloride) Duct Coupling. Available sizes are shown below and are manufactured to meet CSA C22.2 No. 211.1.

#### MATERIALS

The couplings are fabricated from PVC (polyvinyl chloride) Hydro Quebec duct with a plain end. The duct pipe is certified to the Canadian Standards Association (CSA) standard C22.2 No.211.1 and manufactured according to Hydro Quebec B.31.21.1-01.

#### MARKING

Markings on the couplings are as specified in CSA C22.2 No. 211.1.

#### TEST REQUIREMENTS

Quality testing is as per Royal's Quality Control program and in accordance with CSA C22.2 No. 211.1.

#### FITTING DIMENSIONS

Nominal Size (in)	Part Number	Length (L) (in)
4 ½	QWC045	4.972

