



131 Regalcrest Court
Woodbridge, ON L4L 8P3
Tel: (905) 856-7550
Fax: (905) 856-4367
Toll free: 1-800-263-2353

TECHNICAL SPECIFICATION

PVC Rigid Conduit, Octagonal Boxes ROB15/10, ROB20

SCOPE

This specification covers the requirements for Rigid PVC (polyvinyl chloride) Conduit Octagonal Boxes in ½", ¾" and 1" sizes. Included with the box is the gasket, cover and screws (for mounting of cover).

MATERIALS

The box and cover are injection molded from virgin PVC compound. The gasket is injection molded from virgin flexible PVC compound.

PVC material used in the manufacture of the box and cover is UV and impact resistant.

CERTIFICATIONS

This part is certified to the following standards:

Canadian Standards Association:


- Certified to CSA C22.2 No. 18 and 85
- Certified as Rain-Tight

Underwriter's Laboratories Inc.:

- Certified to UL 514C
- Certified for use in Wet Locations

BOX DIMENSIONS

Box dimensions are available upon request.



Prepared: May 2, 2008

By: S. Scott

Revised: N/A